

Prescriptive Crawlspace Air Sealing Installation Checklist

Site Information			Install Date:	
Participant Name:			Participant Phone:	
Site Address:	City:	State:	Zip:	
				Installer
1.	Weatherstripping: Installed between crawl-space access frame and hatch door provides an effective air seal. Durable rigid material and weatherstripping installed if the door isn't supported by a frame on all 4 sides.			
2.	Chases: Sealed with foam, caulk, or rigid moisture-resistant material to the floor or wall. Fire rated materials used at chimneys and flues.			
3.	Duct penetrations: Sealed with mastic, caulk, or other air-tight seal around perimeter of duct boots between the boot and the subfloor.			
4.	Plumbing and electrical penetrations: Sealed with foam or caulk. Rigid, moisture resistant material used to span gaps larger than 1".			
5.	Other open cavities: Rigid material installed to close other open cavities and air sealed to the floor.			
6.	Sill-plate: Sealed to stem-wall connections with foam or caulk.			
7.	Rim-joists: Rigid material installed between rim joists if no blocking is present. Perimeter of each rim joist cavity between basements and crawl spaces foamed or caulked			
Notes:				
By signing below, I certify that the items marked as completed on this checklist were completed for this site.				
Installation Name:			Date:	
Contractor Name (if applicable):		Phone:		