



**NOTES:**

1. CPI PRIMARY AND SECONDARY CONDUIT MUST BE 3 INCH AND COMMUNICATION CONDUIT ARE 2 INCH.
2. CPI COMMUNICATION CONDUIT SHOULD FOLLOW ALL PRIMARY AND SECONDARY ROUTES.
3. 12 INCH SEPARATION REQUIRED BETWEEN UTILITIES, (GAS, WATER, SEWER, TELCO,...)
4. BACK FILL MATERIAL MUST BE FREE OF ROCK AND DEBRIS.

**CPI SINGLE PH. TRENCHING DETAIL  
PRIMARY, SECONDARY, AND COMM.**

DRAWN BY: AGS DATE: 06-07-2018	REVISED BY: DATE:	CHK'D BY: DATE:	APPROVED BY: DATE:
UR2-1PH			SCALE:
			ORIGIN DATE: 06-07-2018

**CONSUMERS POWER INC.**

P.O. Box 1180  
6990 West Hills Rd.  
Philomath, Oregon 97370-1180  
Phone: 541-929-3124

