

Air-Source Heat Pump Retrofits and Upgrades Project Information Form

For Commercial, Industrial, and Agricultural Applications

Instructions: The installation contractor invoice showing order/purchase date and installed cost and AHRI Certificate documenting that the efficiency requirements must be submitted with this form. All projects must be pre-approved.

BUSINESS AND SITE INFORMATION

Customer Name				
Installation Address (Street, City, State, Zip)				
Customer Phone Number				
Building type (Please check one)	<input type="checkbox"/> Office <input type="checkbox"/> Warehouse <input type="checkbox"/> Residential Care	<input type="checkbox"/> Retail <input type="checkbox"/> Food Service <input type="checkbox"/> Assembly	<input type="checkbox"/> Grocery <input type="checkbox"/> Hospital <input type="checkbox"/> Other (describe):	<input type="checkbox"/> Lodging <input type="checkbox"/> School

PROJECT INFORMATION

For additional equipment, use an additional form.

Project Information	Heat Pump 1	Heat Pump 2
Project Type (Please check one)	<input type="checkbox"/> HP Retrofit <input type="checkbox"/> HP Upgrade	<input type="checkbox"/> HP Retrofit <input type="checkbox"/> HP Upgrade
For HP Retrofits, what was primary heating system type? (Please check one)	<input type="checkbox"/> Electric zonal <input type="checkbox"/> Electric forced air furnace	<input type="checkbox"/> Electric zonal <input type="checkbox"/> Electric forced air furnace
For HP Upgrades, what was primary heating system type? (Please check one)	<input type="checkbox"/> Air source heat pump <input type="checkbox"/> N/A (New construction or major renovation)	<input type="checkbox"/> Air source heat pump <input type="checkbox"/> N/A (New construction or major renovation)
Manufacturer		
Model		
Outdoor unit cooling capacity (tons)		
Installed cost (per attached invoice)		
Order/purchase date (per attached invoice)		

EQUIPMENT SIZE (COOLING CAPACITY; BTU/H)	MODE	SUB-CATEGORY OR RATING CONDITION	EFFICIENCY REQUIREMENT
< 65,000	Cooling	Split System and Single Package	16.0 SEER
	Heating	Split System	9.0 HSPF
		Single Package	8.8 HSPF
≥ 65,000 and < 135,000	Cooling	Split System and Single Package	14.0 IEER
	Heating	47°F db/43°F wb Outdoor Air	3.5 COP
		17°F db/15°F wb Outdoor Air	2.4 COP
≥ 135,000	Cooling	Split System and Single Package	12.5 IEER
	Heating	47°F db/43°F wb Outdoor Air	3.4 COP
		17°F db/15°F wb Outdoor Air	2.4 COP